

August 11, 2014

Page 1 of 1
Our File: 534-285

**DISTRICT OF LILLOOET
WATER SOURCE REPLACEMENT
CONTRACT #4
FILTRATION TREATMENT PLANT**

**CONTRACT DOCUMENTS AND SPECIFICATIONS
ADDENDUM #2**

This Addendum is being issued prior to the closing of Tenders and is intended as clarification and/or revision of the Contract Documents. This Addendum shall become an integral part of the Contract Documents and Tenderers shall acknowledge receipt on the appropriate page of the Form of Tender.

- (1) The Tender Closing Date has been extended to Tuesday, September 9, 2014 at 2:00 PM at the District of Lillooet offices.
- (2) James Hardie Board will be accepted as an alternate to Certainteed Cement Fibre Board. Colours to match those specified and as directed by the Architect.
- (3) Couplings to be applied to SCH80 PVC Pipe shall be Victaulic Style 77 Flexible Grooved Coupling or approved equal. Notes on drawings shall be updated during Issued for Construction for the successful contractor.
- (4) Vic-Press for SCH10 S.S. shall be accepted as an alternate to S.S. tubing for the compressed air lines.
- (5) Iwaki America shall be accepted as an alternative manufacturer for materials supplied under Section 22 11 26 Bulk Chemical Transfer Pump
- (6) The Preliminary Structural Drawings have been removed from the set and Issued for Tender Structural Drawings 534-285-S1 thru -S9, revision C, have been issued.
- (7) Electrical Drawings 534-285-E4 thru -E7 have been revised and reissued.
- (8) Drawing 534-285-G1, Title Page, has been reissued to reflect the update in the drawing set.



Steve Underwood, P. Eng.

SU/dg

Enclosures

R:\Clients\500-599\534\534-285\07 Contract\Water Source Replacement - Contract 4 - Water Treatment Facility Expansion\Addendum 1\534-285 Addendum #1.doc